

# Certificate of Compliance

Certificate Number 1209005-EX6973

Report Reference Ex6973

Issue Date 2005 December 9

Page 1 of 2



**Underwriters  
Laboratories Inc.**

*Issued to:*

## Shanghai Jindun Fire Fighting

Security Service Co., Ltd. \*\*\* 365 Henggiao Road \*\*\* Zhoupu Nanhui  
Shanghai, China 201318

*This is to certify that  
representative samples of*

## Automatic Sprinklers

For use in accordance with the National Fire Protection Association's Standard  
For The Installation of Sprinkler Systems, NFPA 13.

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*


*Standard(s) for Safety:*

In accordance with the requirements in the Standard for Automatic Sprinklers  
for Fire Protection Service, UL 199 Eleventh Edition.

*Additional Information:*

See Addendum pg. 2

Only those products bearing the UL Listing Mark should be considered as being  
covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle;  
 with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and  
the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:  
**John Serpe**

Underwriters Laboratories Inc.

Reviewed by:

**Michael G. McCormick**

Underwriters Laboratories Inc.


# Certificate of Compliance

Certificate Number 1209005-EX6973

Report Reference Ex6973

Issue Date 2005 December 9

Page 2 of 2



## UPRIGHT AND PENDENT STANDARD SPRAY SPRINKLERS NOMINAL 5.6 K-FACTOR

SIN	Response Type	Type	System Working	
			Pressure, psig.	Temp. Rating, °F
JD001	SR	Upright	175	155, 175, 200
JD002	QR	Upright	175	155, 175, 200
JD003	SR	Pendent	175	155, 175, 200
JD004	QR	Pendent	175	155, 175, 200

## STANDARD SIDEWALL SPRAY SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	System Working	
				Pressure, psig	Temp. Rating, °F
JD005	SR	Horizontal	5.6	175	155, 175, 200
JD006	QR	Horizontal	5.6	175	155, 175, 200

Issued by:  
John Serpe

Underwriters Laboratories Inc.

A handwritten signature in black ink, appearing to read 'John R. Serpe', is written over the printed name and company name.

Reviewed by:  
Michael G. McCormick

Underwriters Laboratories Inc.

A handwritten signature in black ink, appearing to read 'Michael G. McCormick', is written over the printed name and company name.